



SGS COLOMBIA S.A.S.
CRS-F490101
ORDEN No. 4200-32345
CERTIFICADO No. CRS17189
ORDEN CERT. No. CO-CERT210100073-01
CERTIFICADO DE CONFORMIDAD DE PRODUCTO
ATSEI de Colombia Ltda.
Calle 76 No. 32 - 05, Bogotá, Cundinamarca, Colombia

Certifica que el producto identificado como Unidades de Potencia Ininterrumpida (UPS), importados y/o fabricados y comercializados en Colombia por ATSEI de Colombia Ltda., con referencias relacionadas en las siguientes páginas del presente documento, han sido evaluados de conformidad con:

Resolución 90708 del 30 Agosto de 2013 del Ministerio de Minas y Energía - por lo cual se expide el Reglamento Técnico de Instalaciones Eléctricas - RETIE.
Numeral 20.26 UNIDADES DE POTENCIA ININTERRUMPIDA (UPS)

Estos productos han sido sometidos a toma de muestras, inspección, ejecución de pruebas de laboratorio y evaluación del sistema de gestión de calidad del fabricante de acuerdo con el esquema de certificación 5 de la norma ISO/IEC 17067:2013.

Resultados obtenidos: CONFORME

Autorizado por:

SGS COLOMBIA S.A.S.

Camilo Ramirez
SGS Colombia S.A.S.
Carrera 100 No. 25C-11, Bodega 3
Bogotá D.C., Colombia

Fecha de Emisión: 2021-01-28
Fecha de Vencimiento: 2024-01-28
Versión 1

Página 1 de 2



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to co.servicioalcliente@sgs.com, via phone No. 7422274 ext. 13602 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

CRS-C-06-05 V.4 junio 2019



SGS COLOMBIA S.A.S.

CRS-F490101

ORDEN No. 4200-32345

CERTIFICADO No. CRS17189

ORDEN CERT. No. CO-CERT210100073-01

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

ATSEI de Colombia Ltda.

Calle 76 No. 32 - 05, Bogotá, Cundinamarca, Colombia

Unidades de Potencia Ininterrumpida (UPS)

Fabricadas por ATSEI de Colombia Ltda.

Calle 76 No. 32 - 05, Bogotá, Cundinamarca, Colombia

Referencia	Descripción	Estándar De Ensayo	Factor De Potencia	Número De Fases	Potencia Activa (Kw)	Potencia Aparente (Kva)	Temperatura De Operación (°C)	Tensión Nominal De Salida (V)
IRADIUM03	On – Line	IEC62040-3	0.8	3	2.4	3	0-40	120/208
IRADIUM06	On – Line	IEC62040-3	0.8	3	4.8	6	0-40	120/208
IRADIUM10	On – Line	IEC62040-3	0.8	3	8	10	0-40	120/208
IRADIUM100	On – Line	IEC62040-3	0.8	3	80	100	0-40	120/208
IRADIUM15	On – Line	IEC62040-3	0.8	3	12	15	0-40	120/208
IRADIUM20	On – Line	IEC62040-3	0.8	3	16	20	0-40	120/208
IRADIUM30	On – Line	IEC62040-3	0.8	3	24	30	0-40	120/208
IRADIUM40	On – Line	IEC62040-3	0.8	3	32	40	0-40	120/208
IRADIUM50	On – Line	IEC62040-3	0.8	3	40	50	0-40	120/208
IRADIUM60	On – Line	IEC62040-3	0.8	3	48	60	0-40	120/208
IRADIUM80	On – Line	IEC62040-3	0.8	3	64	80	0-40	120/208

FIN DEL DOCUMENTO

Fecha de Emisión: 2021-01-28

Fecha de Vencimiento: 2024-01-28

Versión 1

Página 2 de 2



CRS-C-06-05 V.4 junio 2019